



Material Engineering Laboratory-Taichung



Testing Laboratory
0292

TEST REPORT

Report NO. : TB-14-01013ZA
C-14-04600
Page NO. : 1 OF 1
Date : Mar. 26,2014

Project Name : Self Evaluation
 Contractor : -----
 Applicant : Keding Enterprises Co., Ltd
 Supplier : -----
 Sample Name : Keding Prefinished Veneered Panels
 Sample Submitted By : Keding Enterprises Co., Ltd - Claire Ji
 Date of Sample Received : Mar. 10,2014
 Date of Testing : Mar. 10,2014 ~ Mar. 26,2014
 Remark : 1.The information mentioned in the above section is provided by Applicant
 (Exclude Date of Sample Received and Date of Testing)
 2.The sample was transferred by SGS M&E Laboratory-Taipei
 (Application No.HB-14-01917W C-14-06187. Received date : Mar. 6,2014)
 for the testing item(s) as below to be performed in SGS M&E-Laboratory-Taichung.

Test Results :

Test Item	Test Results	Method Detection Limit (MDL)	Test Method
Emission of formaldehyde-Maximum (mg/L)	0.1	0.05	CNS 8058(2008)
Emission of formaldehyde-Average (mg/L)	0.1	0.05	

Note1 : The F₁ standard values for CNS 8058(2008) of Emission of formaldehyde Maximum ≤ 0.4 mg/L, Average ≤ 0.3 mg/L.
 Note2 : The F₂ standard values for CNS 8058(2008) of Emission of formaldehyde Maximum ≤ 0.7 mg/L, Average ≤ 0.5 mg/L.
 Note3 : The F₃ standard values for CNS 8058(2008) of Emission of formaldehyde Maximum ≤ 2.1 mg/L, Average ≤ 1.5 mg/L.
 Note4 : This test report is an additional original report of TB-14-01013Z C-14-04600 . Issued date : May 12,2015.

-----oOo-----

The required specification(s) offered in this test report is/are for reference only.
The conformity judgment is at the Applicant's final verdict.

Signed for and on behalf of
 SGS TAIWAN Ltd.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

dot-s-ou-1400